

Company: Company

Project: IE HECTOR MANUEL VIDES BALLESTEROS (MÓDULO 9)

File: C:\IE REGIDOR\MOD9.rcb

Engineer: Name

10:34:18 a. m. 27/06/2025

WIND LOADS NSR-10

Wind pressure

$$p = q G C_p \text{ rigid buildings}$$

$$= q G_f C_p \text{ flexible buildings}$$

$$q_z = 0.00483 K_z K_{zt} K_d V^2 I \text{ (Kg/m}^2\text{); } V \text{ in Km/h}$$

WIND LOADING PARAMETERS

Basic wind speed (Km/h), V = 125

V: 3-second gust speed at 10 m, with annual probability of 0.002

Importance factor, I = 1.15

OCCUPANCY CATEGORY	IMPORTANCE (1)	F A C T O R (2)
I Normal occupancy buildings	0.87	0.77
II Especial occupancy buildings	1.00	1.00
III Public assistance facilities	1.15	1.15
IV Essential facilities	1.15	1.15
(1): Non-hurricane prone regions with V=140-160 km/h		
(2): Hurricane prone regions with V >160 Km/h		

Exposure category = C

ROUGHNESS	DESCRIPTION
B	Urban and suburban areas, wooded areas, obstructions >30ft
C	Open terrain with scattered obstructions less than 30 ft
D	Flat, unobstructed areas, wind over large bodies of water

Directionality factor, K_d = 0.85Topographic factor, K_{zt} = 1.0

$$K_{zt} = (1 + K_1 K_2 K_3)^2$$

Wall pressure coefficients, C_p

Windward wall	 = 0.8
Leeward wall (Wind X)	 = -0.38
Leeward wall (Wind Y)	 = -0.5
Side walls	 = -0.7
Roof	 = 0.0

GUST EFFECTS FACTORS

Basic wind velocity, (Km/h) = 125

Exposure category = C

Exposed height, (m) = 3.3

	X-direction -----	Y-direction -----	
Computed natural frequency, f (Hz) =	5	5.236	
Height / Length ratio, H/L =	.333	.534	
Structure clasification =	RIGID	RIGID	
Background response index, Q =	.936	.923	(Eq. B.6.5-4)
Resonant response factor, R ₁ *.... =	.134	.102	(Eq. B.6.5-8)
Gh: Rigid - Simplified analysis .. =	.85	.85	(Sec B.6.5.8.1)
Gh: Rigid - Complete analysis =	.889	.881	(Eq. B.6.5-2)
Gf: Flexible -Analytical(2% dampng)=	1.072	1.063	(Eq. B.6.5-6)
Gf: Flexible -Analytical(1% dampng)=	1.075	1.064	(Eq. B.6.5-6)
Gust effects factor, G =	.889	.881	

* 1% damping ratio. For damping ratio β, R = R₁ * (0.01/β)^{1/2}

Company: Company
Project: IE HECTOR MANUEL VIDES BALLESTEROS (MÓDULO 9)

Engineer: Name
10:34:19 a. m. 27/06/2025

VELOCITYPRESSURE

Floor	Height	Pressure
-	z, m	qz, K/m2
-----	-----	-----
2	3.29	63.297
1	0.0	63.297

ACCIDENTAL TORSION FOR WIND LOADS

	X-direction	Y-direction
	-----	-----
Accidental eccentricity as a percentage of building dimension, (%)=	15	15

WY is Envelope of:
Case 1: Pwy + Ply
Case 2: 0.75 (Pwy + Ply) + Mt
Mt=0.75(Pwy+Ply)Bx ex

WX is Envelope of:
Case 1: Pwx + Plx
Case 2: 0.75 (Pwx + Plx) + Mt
Mt=0.75 (Pwx+Plx)By ey

NOTE: Load cases 3 and 4 are handled through load combinations

ACCIDENTAL ECCENTRICITY WIND LOADS

	X-DIRECTION (WY)	Y-DIRECTION (WX)
	-----	-----
Level	ex	ey
-	(m)	(m)
-----	-----	-----
2	1.48	0.93

WY is Envelope of:
Case 1: Pwy + Ply
Case 2: 0.75 (Pwy + Ply) + Mt
Mt=0.75(Pwy+Ply)Bx ex

WX is Envelope of:
Case 1: Pwx + Plx
Case 2: 0.75 (Pwx + Plx) + Mt
Mt=0.75 (Pwx+Plx)By ey

NOTE: Load cases 3 and 4 are handled through load combinations

Company: Company
Project: IE HECTOR MANUEL VIDES BALLESTEROS (MÓDULO 9)

Engineer: Name
10:34:19 a. m. 27/06/2025

Wind nodal forces:

$P_w = \sum p_z A_i$
 $P_s = \sum p_h A_i$
 $A_i = \text{Nodal tributary area}$

$P_l = \sum p_h A_i$
 $P_r = \sum p_h A_i$

W I N D F O R C E S : X - D I R E C T I O N					
Floor No	Height z, m	Windward Pw, Ton	Leeward Pl, Ton	Side Ps, Ton	Roof Pr, Ton
2	3.29	0.46	0.22	0.64	0.0
1	0.0	0.37	0.18	0.21	0.0

Base shear, $V:\sum(P_w+P_l) \dots = 1.22 \text{ ton}$

Building Weight, $W \dots = 52.06 \text{ ton} \quad (V/W = 0.023)$

Overturning moment

From horizontal forces $\dots = 2.23 \text{ ton-m}$

From roof forces $\dots = 0.0 \text{ ton-m}$

Total moment, $M_o \dots = 2.23 \text{ ton-m}$

Stabilizing moment, $M_s \dots = 202.69 \text{ ton-m} \quad (M_o/M_s = 0.011)$

Company: Company

Project: IE HECTOR MANUEL VIDES BALLESTEROS (MÓDULO 9)

Engineer: Name

10:34:19 a. m. 27/06/2025

Wind nodal forces:

$P_w = \sum p_z A_i$

$P_s = \sum p_h A_i$

$A_i = \text{Nodal tributary area}$

$P_l = \sum p_h A_i$

$P_r = \sum p_h A_i$

W I N D F O R C E S : Y - D I R E C T I O N					
Floor No	Height z, m	Windward Pw, Ton	Leeward Pl, Ton	Side Ps, Ton	Roof Pr, Ton
2	3.29	0.73	0.46	0.40	0.0
1	0.0	0.24	0.15	0.32	0.0

Base shear, $V:\sum(P_w+P_l)$.. = 1.58 ton

Building Weight, W = 52.06 ton ($V/W = 0.030$)

Overturning moment

From horizontal forces . = 3.91 ton-m

From roof forces = 0.0 ton-m

Total moment, Mo = 3.91 ton-m

Stabilizing moment, Ms.... = 160.38 ton-m ($Mo/M_s = 0.024$)