Company: Company Engineer: Name
Project: IE HECTOR MANUEL VIDES BALLESTEROS (MÓDULO 3) 5:12:09 p. m. 26/06/2025
File: C:\IE REGIDOR\MOD3.rcb

DRIFT-BASED FLEXIBLE-STORY CHECK - NSR-10

	EARTHQUAKE - X				EARTHQUAKE - Y			
Story	Δcm*	Δcm/h	Δn/Δn+1	Irregular	Δcm*	Δcm/h	Δn/Δn+1	Irregular
1	1.2437	0.0034	-	-	0.6815	0.0019	-	-

* Δcm: Story drift at center of mass (cm)
n/n+1 Δ/h: (Δcm/h)n/(Δcm/h)n+1: Ratio between drift ratio at CM of a stotry and that of story above

Vertical irregularities type 1a, 1b, 2 and 3 do not apply if drift ratio of each story is less than 1.3 that of next story above (i.e. n/n+1 Δ/h < 1.3). Story drift ratio of top two stories are not considered

Stiffness-based flexible story check is not required!
It can be considered that vertical irregularities type 1aA, 1bA, 2A and 3A DO NOT EXIST !

Use: Øa = 1

STORY STIFFNESS-BASED ON DESIGN SHEAR

	X-DIRECTION			Y-DIRECTION		
Story	Shear X	Δcm X	Kx	Shear Y	Δcm Y	Ky
1	99.4	1.2437	79.9	99.4	0.6815	145.9

Shear: Design Shear, in ton
Δcm: Drift at center of mass, in cm
K: Story stiffness, in ton/cm

STIFFNESS-BASED FLEXIBLE-STORY CHECK - NSR-10

	EARTHQUAKE - X				EARTHQUAKE - Y			
Story	Kn	Kn/Kn+1	Kn/Kavg3	Irregular	Kn	Kn/Kn+1	Kn/Kavg3	Irregular
1	79.9	-	-	-	145.9	-	-	-

Kn: Stiffness of story n, in ton/cm
Kn/Kn+1: Ratio between stiffness of story n and that of store above n
Kn/Kavg3: Ratio between stiffness of story n and average stiffness of three stories above n

Stiffness-soft story irregularity is considered to exist if Kn/Kn+1 < 0.7 or Kn/Kavg3 < 0.8
Stiffness-EXTreme soft story irregularity is considered to exist if Kn/Kn+1 < 0.6 or Kn/Kavg3 < 0.7

Stiffness-flexible story irregularity types 1aA and 1bA do NOT exist.

Notes:
The determination stiffness-soft story irregularity (vertical structural irregularity types 1a and 1b) is conducted based on story-stiffness computed for the design seismic shear distribution, according to FEMA's NEHRP Recommended Provitions for Seismic Regulations for New Buildings and other Structures, Provisions and Commentary ed. 1994, 1997, 2000, 2003, 2009, which is applicable to the following building codes derived from the above documents: (USA) IBC-03/06, ASCE 7-05/10, CBC-01/07, UBC-97, (COLOMBIA) NSR-10, (PAN) REP-2004/2014/2021 (DOM) R-001, (GUA) NSE10.

WEIGHT (MASS) IRREGULARITY CHECK

Floor	Wn	Wn/Wn+1	Wn/Wn-1	Irregular
2	138.3	-	-	-

Wn: Effective weight of floor n, in ton

Wn/Wn+1: Ratio between weight of floor n and weight of floor above n
Wn/Wn-1: Ratio between weight of floor n and weight of floor below n

Weight (mass) irregularity is considered to exist if effective weight of any floory is more than 1.5 times the effective weight of an adjacent floor. That is, if Wn/Wn+1 > 1.5 or Wn/Wn-1 > 1.5.
A roof that is lighter than the floor below is not considered.

Weight (mass) irregularity (2A) does NOT exist.